

## Test Method 319

<b>Test Method 319 Results</b>		
<b>Particle Size (Microns)</b>	<b>NESHAP Efficiency Requirements for Existing Systems</b>	<b>OSM-200 Efficiency</b>
<b>Liquids</b>		
> 2.2	> 10%	27%
> 4.1	> 50%	80%
> 5.7	> 90%	96%
<b>Solids</b>		
> 2.6	> 10%	24%
> 5.0	> 50%	70%
> 8.1	> 90%	93%